



# UNITED ENGINEERING CONSULTANTS, INC.

- Building Condition Surveys
- Contract Administration
- Corrosion Control Design
- Structural Inspection & Design
- Project Planning & Management

## FIELD OBSERVATION REPORT

PERMIT # BLDC-00620-2022


		Report No. 96	Page 1 of 1
Project:	Oceans West One Condominium	Inspection For:	Building Repair and WP Project
Day/Date:	Thursday, November 16, 2023	Job No.	20-1153
Location:	1 Oceans West Blvd. DBS, FL 32118	Engineer:	Christopher B. Longman, P.E.
Contractor:	SPEC Contractor Services	Project Foreman:	Hans / Ken Certain
Subcontractor:	None	Inspector:	Christopher B. Longman, P.E.
Weather:	74 Degrees @ 11:30 A.M.	Overcast	Breezy winds Rain showers
Workforce Total:	4		
Activities:	Parking garage shoring installation		

### Observation Report:

All garage shoring is complete. The crew is working on general clean-up and installing caution tape and signage. The items noted in the last report that required correction were re-inspected and verified to be complete. The last section of shoring, located below the amenities deck, was inspected. All shores were installed at the correct spacing and location. Minor adjustments to plumb some shores were directed to be completed. All elevated slabs are open to vehicular and resident use. The Contractor has been contracted to monitor and maintain the shoring on a regular basis while the shoring remains in-place.

UNITED ENGINEERING CONSULTANTS

Christopher B. Longman, P.E.  
Florida License No. 82452



This item has been electronically signed and sealed by Christopher B. Longman using a digital signature and date. Printed copies of this document are not considered signed and sealed and the SHA authentication code must be verified on any electronic copies.